


NOTES:

- 1) COMPONENTS ARE CONNECTED WITH FLAME-RETARDANT SWITCHBOARD INSULATION SYSTEM (SIS) TYPE WIRING, IDENTIFIED ON EACH END WITH NUMBER-CODED MARKERS. GROUND WIRES ARE GREEN WITH YELLOW STRIPE.
- 2) POWER WIRES # 137, 138 & 139 ARE #14 AWG
ALL OTHER SIGNAL WIRING IS #18 AWG
- 3) TB1 (DC+/-) TERMINAL BLOCK IS MOLDED PHENOLIC BARRIER TYPE WITH 6-32 COMPRESSION SCREWS, ACCEPTING RING OR SPADE LUGS FOR #22-16 AWG WIRE.
- 4) TB2 (VENT/FAN) TERMINAL BLOCK IS NYLON SECTIONAL TYPE WITH TUBULAR COMPRESSION SCREWS, ACCEPTING #18-8 AWG WIRE.
- 5) VENT/FAN CONTROL ASSEMBLY IS NOT A UL, CSA, CE, OR NRTL LISTED UNIT.
- 6) SEE JA5052-10 FOR INSTALLATION & OPERATING INSTRUCTIONS.



| | | | | | |
|-----|--------|---|---|--|--|
| | | THIRD ANGLE PROJECTION | | TITLE EXTERNAL VENT/FAN CONTROL ASSY: SCHEMATIC / CONNECTION DIAGRAM: EJ5017-26 | |
| | | DRAWN BY MCR 031920 | DRAWING No JE5120-26 REV A B | | |
| | | ELECTRONIC APPROVAL SIGNATURES MAINTAINED BY MFG ECN LOG | | SCALE NTS PART No JE5120-26 SHEET 1 OF 1 | |
| A | -N/A- | 031920 | UNLESS OTHERWISE NOTED DIMENSIONS ARE IN INCHES. TOLERANCES ARE: | | |
| REV | ECN No | DATE | | | |