



- NOTES:
- COMPONENTS ARE CONNECTED WITH FLAME-RETARDANT SWITCHBOARD INSULATION SYSTEM (SIS) TYPE WIRING, IDENTIFIED ON EACH END WITH NUMBER-CODED MARKERS. GROUND WIRES ARE GREEN WITH YELLOW STRIPE.
  - POWER WIRES # 137, 138 & 139 ARE #12 AWG ALL OTHER SIGNAL WIRING IS #18 AWG
  - TB1 (DC+/-) TERMINAL BLOCK IS MOLDED PHENOLIC BARRIER TYPE WITH 6-32 COMPRESSION SCREWS, ACCEPTING RING OR SPADE LUGS FOR #22-16 AWG WIRE.
  - TB2 (VENT/FAN) TERMINAL BLOCK IS NYLON SECTIONAL TYPE WITH TUBULAR COMPRESSION SCREWS, ACCEPTING #18-8 AWG WIRE.
  - VENT/FAN CONTROL ASSEMBLY IS NOT A UL, CSA, CE, OR NRTL LISTED UNIT.
  - SEE JA5052-10 FOR INSTALLATION & OPERATING INSTRUCTIONS.

		THIRD ANGLE PROJECTION		TITLE	
DRAWN BY		MCR 102319		EXTERNAL VENT/FAN CONTROL ASSY: SCHEMATIC / CONNECTION DIAGRAM: EJ5017-36	
ELECTRONIC APPROVAL SIGNATURES MAINTAINED BY MFG ECN LOG		DRAWING No		REV	
UNLESS OTHERWISE NOTED DIMENSIONS ARE IN INCHES. TOLERANCES ARE:		JE5120-36		A B	
REV	ECN No	DATE	SCALE	PART No	SHEET
			NTS	JE5120-36	1 OF 1